



TM

Ref. Certif. No.

HU-003305

**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME****CB TEST CERTIFICATE**

Product

Surge Protective Device

Name and address of the applicant

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing, 325603 Zhejiang, P.R. China

Name and address of the manufacturer

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing, 325603 Zhejiang, P.R. China

Name and address of the factory

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing, 325603 Zhejiang, P.R. China

Ratings and principal characteristics

UC: 275 V AC (L-N/PE) 255 V AC (N-PE) UP:1.5 kV
Class II: In: 20 kA, I_{max}: 50 kA,
Class I: Max: L-N I_{imp}: 12.5kA; N-PE I_{imp}: 12.5kA or 50kA
IP20, one port SPD, indoor, -40 °C ...+70 °C, I_{sc}cr: 25 kA

Trademark (if any)

LEEYEE

Customer's Testing Facility (CTF) Stage used

N/A

Model / Type Ref.

LY1-12.5/1+1, LY1-12.5/1S+1, LY1-12.5/3+1, LY1-12.5/3S+1
LY1-12.5/1, LY1-12.5/1S, LY1-12.5/3, LY1-12.5/3S,
LY1-12.5/4, LY1-12.5/4S
LY1-7/1+1, LY1-7/1S+1, LY1-7/3+1, LY1-7/3S+1
LY1-7/1, LY1-7/1S, LY1-7/3, LY1-7/3S, LY1-7/4, LY1-7/4SAdditional information (if necessary may
also be reported on page 2)

Detailed information refer to test report CN21XE20 001

A sample of the product was tested and
found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which
forms part of this Certificate

CN21XE20 001

This CB Test Certificate is issued by the National Certification Body

TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2021-02-23

Signature:

Wencai Zhang