

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50488349

Blatt *Sheet*
0001

Ihr Zeichen *Client Reference*
S.F.Q.

Unser Zeichen *Our Reference*
01-Wuchale-CN20PX06 001

Ausstellungsdatum
04.12.2020

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

WENZHOUEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

WENZHOUEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 61643-11:2012+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Surge Protector (Surge Protective Device)

Type Designation: 1) LY1-C40/1+1, LY1-C40/1S+1
LY1-C40/3+1, LY1-C40/3S+1
2) LY1-C40/1, LY1-C40/1S
LY1-C40/3, LY1-C40/3S
LY1-C40/4, LY1-C40/4S
3) LY1-D20/1+1, LY1-D20/1S+1
LY1-D20/3+1, LY1-S20/3S+1
4) LY1-D20/1, LY1-D20/1S
LY1-D20/3, LY1-D20/3S
LY1-D20/4, LY1-D20/4S

8

Trade mark : LEEYEE
Uc : AC 275 V(L-N/PE) ; AC 255 V(N-PE)
Continued on page 0002



8

ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

Zertifizierungsstelle

Zhao Xinhua

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

WENZHOU LEEYEE ELECTRIC CO., LTD.
Mr. Sun Funqin General Manager
GM office
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Date : 04.12.2020
Our ref. : Wuchale 01
Your ref.: S.F.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Surge Protective Device
Model Designation : See Certificate
Certificate No. : R 50488349 0001
Report No. : CN20PX06 001

Dear Mr. Sun Funqin,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



Zhao Xinhua

cc: WENZHOU LEEYEE ELECTRIC CO., LTD.

Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50488349

Blatt *Sheet*
0002

Ihr Zeichen <i>Client Reference</i>	Unser Zeichen <i>Our Reference</i>	Ausstellungsdatum <i>Date of Issue</i>
S.F.Q.	01-Wuchale-CN20PX06 001	04.12.2020 (day/mo/yr)

Genehmigungsinhaber *License Holder*

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Fertigungsstätte *Manufacturing Plant*

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Prüfzeichen *Test Mark*



Geprüft nach *Tested acc. to*
EN 61643-11:2012+A11

Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Surge Protector (Surge Protective Device)

Continuation from page 0001

Up	: 1.5 kV
Isccr	: 25 kA
In	: 20 kA
Imax	: 40 kA
Type of SPD	: Type 2
Location	: Indoor
Temperature	: -40°C to 70°C



ANLAGE (Appendix): 1.0

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg

Tel.: +49 221 806-1371 e-mail: cert-validity@de.tuv.com
Fax: +49 221 806-3935 http://www.tuv.com/safety

Zertifizierungsstelle

Zhao Xinhua

WENZHOU LEEYEE ELECTRIC CO., LTD.
Mr. Sun Funqin General Manager
GM office
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Date : 04.12.2020
Our ref. : Wuchale 01
Your ref.: S.F.Q.

Ref : R TÜV-Mark Approval

Type of Equipment : Surge Protective Device
Model Designation : See Certificate
Certificate No. : R 50488349 0002
Report No. : CN20PX06 001

Dear Mr. Sun Funqin,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



Zhao Xinhua

cc: WENZHOU LEEYEE ELECTRIC CO., LTD.

Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询

CERTIFICATE

of Conformity Low Voltage Directive 2014/35/EU

Registration No.: AN 50488357 0001

Report No.: CN20PX06 001

Holder: WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Product: Surge Protector
(Surge Protective Device)

Identification: Type Designation: 1) LY1-C40/X+1, LY1-C40/XS+1
2) LY1-C40/Y, LY1-C40/YS
3) LY1-D20/X+1, LY1-D20/XS+1
4) LY1-D20/Y, LY1-D20/YS
X can be 1,3; Y can be 1,3,4
Serial No. : Engineering Samples
Remark: this certificate issued together with R50488349 0001

This certificate of conformity is based on an evaluation of a sample of the above mentioned product. Technical Report and documentation are at the Licence Holder's disposal. This is to certify that the tested sample is in conformity with Annex I of Council Directive 2014/35/EU, referred to as the Low Voltage Directive. This certificate does not imply assessment of the series-production of the product and does not permit the use of a TÜV Rheinland mark of conformity. The holder of the certificate is authorized to use this certificate in connection with the EC declaration of conformity according to Annex IV of the Directive.



Certification Body



Zhao Xinhua

Date 04.12.2020

TÜV Rheinland LGA Products GmbH - Tillystraße 2 - 90431 Nürnberg

WENZHOU LEEYEE ELECTRIC CO., LTD.
Mr. Sun Funqin, General Manager
GM office
No. 1, Xingye Road, Dagang,
Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Date : 04.12.2020
Our ref. : Wuchale 01
Your ref.: S.F.Q.

Ref : AN Certificate of Conf. Low Voltage D.

Type of Equipment : Surge Protective Device
Model Designation : See Certificate
Certificate No. : AN 50488357 0001
Report No. : CN20PX06 001

Dear Mr. Sun Funqin,

The above specified equipment has been tested and found to be in accordance with the relevant requirements.

Please find enclosed your certificate as specified above.

If cancellation of the certificate is submitted by 15 November in a given year, no fee will be charged for the following year.

The certificate is issued with the reservation that the license holder applies all information required in § 6 of the ProdSG related to name and address of the manufacturer or his authorized representative / importer, including their respective contact addresses on the product prior to marketing of the product in the European Economic Area.

With kind regards,

Certification Body



Zhao Xinhua

CC: WENZHOU LEEYEE ELECTRIC CO., LTD.

Enclosure

证书的详细资料请登录www.tuvdotcom.com 查阅, 或拨打我司客服热线 800 999 3668/400 883 1300 咨询