

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Surge Protective Device

Name and address of the applicant

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang, Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Name and address of the manufacturer

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang, Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Name and address of the factory

Note: When more than one factory, please report on page 2

WENZHOU LEEYEE ELECTRIC CO., LTD.
No. 1, Xingye Road, Dagang, Beibaixiang Town, Yueqing,
325603 Zhejiang
P.R. China

Ratings and principal characteristics

Uc:1) 275VAC (L-N), 255V (N-PE); 2) 275VAC (L/N-PE)
In: 20kA; Imax: 40kA; Isccr: 25kA
Up: 1) 1.5kV (L-N), 1.2kV (N-PE); 2) 1.5kV (L/N-PE)
Indoor; One port; Class II

Trademark / Brand (if any)

LEEYEE

Customer's Testing Facility (CTF) Stage used

Model / Type Ref.

1) LY1-C40M/1+1, LY1-C40M/3+1
2) LY1-C40M/2, LY1-C40M/4

Additional information (if necessary may also be reported on page 2)

N/A

A sample of the product was tested and found to be in conformity with

IEC 61643-11:2011

As shown in the Test Report Ref. No. which forms part of this Certificate

CN23FALU 001

This CB Test Certificate is issued by the National Certification Body



TÜV Rheinland InterCert Kft., MEEI Division
H-1143 Budapest, Gizella út 51-57., Hungary
Web: www.tuv.com

Date: 2023-09-15

Signature:



Wencai Zhang