

Zertifikat *Certificate*

Zertifikatsnummer Certificate No.:

R 50602134 0001

Berichtsnummer Report No.:

CN23XBIV 001

Genehmigungsinhaber License Holder:

WENZHOU LEEYEE ELECTRIC CO., LTD.

No. 1, Xingye Road, Dagang,

Beibaixiang Town, Yueqing,

325603 Zhejiang

P.R. China

Fertigungsstätte Manufacturing Site:

WENZHOU LEEYEE ELECTRIC CO., LTD.

No. 1, Xingye Road, Dagang,

Beibaixiang Town, Yueqing,

325603 Zhejiang

P.R. China

Prüfzeichen Test Mark:

 Type Approved
 Safety
 Regular Production
 Surveillance

 www.tuv.com
 ID 1111275115

Geprüft nach Tested according to:

EN 61643-11:2012+A11

Geräteidentifikation

Product Identification

Produkt: Surge Protector (Surge Protective Device)

Product:
Modell: Modelle sind auf nächste(r) Seite(n) gelistet

Type: Type designation(s) are listed on the next page(s)

Technische Daten: Uc :1) 275VAC (L-N), 255V(N-PE)
Technical Data: 2) 275VAC(L/N-PE)

In :20kA

Imax :40kA

Iscrr :25kA

Up :1) 1.5kV(L-N), 1.2kV(N-PE)
2) 1.5kV(L/N-PE)

IP code :IP20

Type of SPD:Type 2

Remark: Test according to IEC 61643-11:2011 was considered.

ANLAGE (Appendix): 1.0

Gültig ab: 2023-09-15

Valid from:
Zertifizierungsstelle:
Certification body:
Ausstellungsdatum: 2023-09-15

Date of issue:

Yongming Yang



Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.

This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland LGA Products GmbH, Tillystraße 2, 90431 Nürnberg
<http://www.tuv.com/safety> E-mail: markcheck@tuv.com

Fax: +49 221 806-3935

Zertifikat *Certificate*

Zertifikatsnummer *Certificate No.:*

R 50602134 0001

Berichtsnummer *Report No.:*

CN23XBIV 001

Produkt *Product:*

Surge Protector
(Surge Protective Device)

Modell *Type:*

Bezeichnung *Designation:*

1) LY1-C40M/1+1, LY1-C40M/3+1

2) LY1-C40M/2, LY1-C40M/4

